



Memo No : FES / NAD / 250 / 2025

Dated: 17.04.2025

APPENDIX - XII

FIRE SAFETY CERTIFICATE

Certified that the existing building **Santipur Public School** at Vill. BablaDakshinpara, P.O.-Babla Gobindapur, P.S.- Santipur, Dist.- Nadia, Pin- 741404, West Bengal comprised of **Single (One) Building Block, NIL** basement(s) and **Two**(upper floors)i.e. (G+2)owned/occupied by **Santipur Public School** have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules, and verified by the officers concerned of Fire Service on **17.04.2025** (date of inspection)in the presence of **Mr. Subir Goswami**, 14/2/1, Nischintapur Lane, P.O.- Santipur, P.S.- Santipur, Dist.- Nadia, Pin- 741404, West Bengal (President of the institution) and that the building/premises is fit for occupancy upto classes **XII** with effect from **15.05.2023** for a period of **03 (Three)** years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Name of the school: **SANTIPUR PUBLIC SCHOOL**
2. Way to School: **Available**
3. Entire land comprise of **a single contiguous plot of land**
4. Total Land Area= **14076.54 sq. mt. (3.46 Acres)**
5. Necessary Fire safety certificate has been issued (vide Memo No. **FES/NAD/63/16**, Date-**15/05/2023**) by the **Divisional Fire Officer, Nadia, West Bengal Fire & Emergency Services, Govt. of West Bengal.**
6. Building is having single block (one)

Issued on 17/04/2025 at 1.30 PM by Mr. Subrata Guha

(Signature)
17/04/25
DIVISIONAL FIRE OFFICER
NADIA DIVISION
W.B.F. & E.S.
KRISHNAGAR, NADIA.

Signature with Seal:.....

Name: Mr. Subrata Guha

Designation: Divisional Fire Officer

Name & Address of Department/ Office: West Bengal Fire & Emergency Services, Azad Hind Sadak, Ghurni, Krishnanagar, Nadia, Govt. of West Bengal.

To,

SANTIPUR PUBLIC SCHOOL

Vill.-BablaDakshinpara, P.O.- Babla Gobindapur,

P.S.- Santipur, Dist.- Nadia, Pin- 741404, West Bengal

(Signature)
Subir Goswami
President / Manager
SANTIPUR PUBLIC SCHOOL
Vill.- Babla Dakshinpara, P.O.- Babla Gobindapur
P.S.- Santipur, Dist.- Nadia, Pin-741404, W.B.

(Signature)
Riya Banerjee
Principal
SANTIPUR PUBLIC SCHOOL
Vill.- Babla Dakshinpara, P.O.- Babla Gobindapur
P.S.- Santipur, Dist.- Nadia, Pin-741404, W.B.



Government Of West Bengal
Office Of The Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.- Ghurni, P.S.- Kotwali, Pin :- 741103

Memo no.:FES/NAD/ 63/16

Date: 15-05-2023

From:
Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services

To: Santipur Public School
Plot No. LR 1298(Part) LR 1300, Mouza- Gobindapur, Khatian No. 3677, JL No. 32, Vill:- Babla Dakshinpara, Post:-
Babla Gabindapur, PS:- Santipur, Dist:- Nadia, Pin:- 741404, West Bengal.

Sub: Issuance of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational, in favour of 'SANTIPUR PUBLIC SCHOOL', at the Premises no. Plot No. LR 1298(Part) LR 1300, Mouza- Gobindapur, Khatian No. 3677, JL No. 32, Vill: Babla Dakshinpara, Post: Babla Gabindapur, PS: Santipur, Dist: Nadia, PIN 741404, West Bengal.

This is in reference to your application no. 0125189231000053 dated 07-05-2023 regarding the Issuance of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational, in favour of 'SANTIPUR PUBLIC SCHOOL', at the Premises no. Plot No. LR 1298(Part) LR 1300, Mouza- Gobindapur, Khatian No. 3677, JL No. 32, Vill: Babla Dakshinpara, Post: Babla Gabindapur, PS: Santipur, Dist: Nadia, PIN 741404, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. One Stand by Fire Pump should be arranged with the down comer system within one month.
2. Driveway must be free from any type of obstruction for easy movement of fire appliances.
No parking will be allowed on the drive way.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be maintained strictly.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
6. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.

Riya Banerjee
Principal
SANTIPUR PUBLIC SCHOOL

The authentic and signed copy can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125189231000053

SANTIPUR PUBLIC SCHOOL

Page : 1

Vill.- Babla Dakshinpara, P.O.- Babla Gabindapur

Vill. Babla Dakshinpara, P.O.- Babla Gobindapur
S. Santipur, Dist.- Nadia, Pin-741404, W.B.

Powered By emSigner For secure paperless solutions
Please visit www.emsigner.com

8. Mock Fire practice and evacuation drill shall be performed periodically with participation of all Teaching, Non- Teaching employees and students of the building.

9. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.

10. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

11. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

12. Adequate nos. of Fire Safety Directional Signage's Board and Assembly Point shall be prepared and be displayed at all appropriate places of the building.

13. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

14. Directional sign of escape route shall be displayed prominently.

15. This Fire Safety certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.

Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the FSC shall be treated cancelled.

Signature valid

Digitally signed by SUBRATA
GUHA
Date: 2023.05.15 10:33:49 IST

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services

Subir Goswami
President / Manager
SANTIPUR PUBLIC SCHOOL
Vill.- Babla Dakshinpara, P.O.- Babla Gobindapur
P.S.- Santipur, Dist.- Nadia, Pin-741404, W.B.

Riya Banerjee
Principal
SANTIPUR PUBLIC SCHOOL
Vill.- Babla Dakshinpara, P.O.- Babla Gobindapur
P.S.- Santipur, Dist.- Nadia, Pin-741404, W.B.